



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0036
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

July 9, 2010

Merinda Halladay, Administrator
Belmont Care Center 5th Street
6150 South 5th Street
Pocatello, Idaho 83204

RE: Belmont Care Center 5th Street

Dear Ms. Halladay:

This is to advise you of the findings of the Initial Medicaid/Licensure Fire Life Safety Survey, which was concluded at Belmont Care Center 5th Street, on July 1, 2010.

Enclosed is your copy of a Statement of Deficiencies/Plan of Correction, form CMS-2567, which states that no Medicaid deficiencies were noted at the time of the survey. Also, enclosed is a similar form stating that no State licensure deficiencies were noted at the time of the survey.

Thank you for the courtesies extended to us during our visit. If we can be of any help to you, please call our office at (208)334-6626.

Sincerely,

MARK P. GRIMES
Health Facility Surveyor
Facility Fire Safety and Construction Program

MPG/lj

Enclosures

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

Printed: 07/07/2010
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13G079	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/01/2010
NAME OF PROVIDER OR SUPPLIER BELMONT CARE CENTER 5TH STREET		STREET ADDRESS, CITY, STATE, ZIP CODE 6150 SOUTH 5TH STREET POCATELLO, ID 83204		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>The facility is single story Type V(000) unprotected construction. The building has a complete automatic sprinkler system that was installed on April 28, 2010, in accordance with NFPA 13R, with coverage throughout including closets and bathrooms. There is an automatic fire alarm system with smoke detection throughout and manual pull stations are located at each of the two exits to grade. The fire alarm system is interconnected with the sprinkler system and was installed on April 26, 2010. The facility is currently licensed for 12 ICF/MR beds.</p> <p>The facility was found to be in substantial compliance during the initial certification life safety code survey conducted on July 1, 2010. The facility was surveyed under the Life Safety Code, 2000 Edition, Chapter 32 New Residential Board and Care Occupancies, Impractical Evacuation Capabilities, adopted March 11, 2003 in accordance with 42 CFR 483.470.</p> <p>The initial life safety code survey was conducted by:</p> <p>Taylor Barkley Health facility Surveyor Facility Fire Safety and Construction</p>	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13G079	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/01/2010
NAME OF PROVIDER OR SUPPLIER BELMONT CARE CENTER 5TH STREET			STREET ADDRESS, CITY, STATE, ZIP CODE 6150 SOUTH 5TH STREET POCATELLO, ID 83204		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
M 000	<p>16.03.11 Initial Comments</p> <p>The facility is single story Type V(000) unprotected construction. The building has a complete automatic sprinkler system that was installed on April 28, 2010, in accordance with NFPA 13R, with coverage throughout including closets and bathrooms. There is an automatic fire alarm system with smoke detection throughout and manual pull stations are located at each of the two exits to grade. The fire alarm system is interconnected with the sprinkler system and was installed on April 26, 2010. The facility is currently licensed for 12 ICF/MR beds.</p> <p>The facility was found to be in substantial compliance during the initial licensure life safety code survey conducted on July 1, 2010. The facility was surveyed under the Life Safety Code, 2000 Edition, Chapter 32 New Residential Board and Care Occupancies, Impractical Evacuation Capabilities, and in accordance with IDAPA 16.03.11.</p> <p>The initial life safety code survey was conducted by:</p> <p>Taylor Barkley Health facility Surveyor Facility Fire Safety and Construction</p>	M 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE